



Lee Fire & Rescue Department

Chief of Department Scott M. Nemet • Assistant Chief Joseph P. Lombardo

20 George Bennett Road, Lee, NH 03861

Phone: (603) 659-5411 Fax: (603) 659-9611

"Protecting Yours Like It's Ours"

PLAN REQUIREMENTS

Fire Suppression/ Automatic Sprinkler System

Project Name: _____
Project Address: _____
Code Edition: _____ Date: _____
Tax Map #: _____

All supporting documentation, showing items listed below are required for review. The checklist is based on 2010 Edition of NFPA 13

General (All submissions shall include the following):

- ☐ A copy of dimensioned shop drawings, and submittal data shall be provided with the permit application permitting evaluation of the system PRIOR to installation.
- ☐ Name and address of project or tenant space where system will be installed or modified.
- ☐ Name, address, and telephone number for the designer of the system.
- ☐ Owners Information Certificate Form. (22.1)
- ☐ Drawings are to be uniform in size, dimensioned, and drawn to a recognized scale. (22.1.1)
- ☐ Plans and calculations shall clearly indicate the design standard(s) and edition (ex: NFPA 13, 2010 Edition) used to prepare the submission.
- ☐ Plans shall include a schematic drawing of the fire protection underground showing point of entry into building, size and length of pipe, point of connection to water supply. (Location of referenced water flow test.) Schematic drawing shall also include the location and type of all valves, meters and backflow prevention devices. (22.1.3)
- ☐ Plans and calculations shall clearly show a floor plan of each story, indicating the location of all walls, partitions, and fire rated assemblies; and the intended use of each area, room or void space. (22.1.3)
- ☐ A dimensioned reflective ceiling plan complete with shadow gram of all walls and obstructions shall be submitted indicating the placement of all sprinkler heads shall be provided.
- ☐ Plans shall indicate the location and pipe size of the device, located downstream of all backflow prevention valves, used to verify the full flow system demand in accordance with (22.1.3(41))



Lee Fire & Rescue Department

Chief of Department Scott M. Nemet • Assistant Chief Joseph P. Lombardo

20 George Bennett Road, Lee, NH 03861

Phone: (603) 659-5411 Fax: (603) 659-9611

"Protecting Yours Like It's Ours"

- ☐ Plans shall clearly indicate total area protected by each system riser on each floor (22.1.3(41))
- ☐ Plans shall include full height cross-section elevation details indicating construction and vertical/ horizontal distances of sprinklers relative to underside of roof/ceiling and structural members. (obstructed or unobstructed) (22.1.3(4))
- ☐ Plans shall clearly indicate the type and location of all control valves, drains valves, test connections, hose outlets, and related equipment and piping. (22.1.3(23))
- ☐ Plans shall clearly indicate the location and type of audible and/or visual alarm devices located inside and outside of the building. (22.1.3(26))
- ☐ Plans shall clearly indicate the make, model, temperature rating, nominal hydraulic K-factor, sprinkler identification number, and quantity of each type of sprinkler to be installed. (22.1.3(12))
- ☐ Plans shall clearly indicate the location of special sprinklers (Examples: extended coverage, sidewall, intermediate/high temperature sprinklers). (22.1.3(13))
- ☐ Plans shall clearly indicate pipe types and wall thickness, type of fittings and joints, and the type and locations of hangers, sleeves, braces, and methods to support sprinkler components. (22.1.3(18)(22))
- ☐ Plans shall clearly indicate nominal pipe size and cutting lengths of pip (center to center), including riser nipples, drop nipples, and armovers. (22.1.3(4))
- ☐ Plans shall clearly indicate method of protection for non-metallic piping as required by pipe manufacturer. (nailer plates and/ or thermal insulation) (22.1.3(4))
- ☐ Plans shall clearly indicate method of maintaining minimum temperature of 40F for sprinkler system piping installed in unconditioned spaces. (7.2.2(3)) (Special note: tenting method requires properly secured, minimum R-30 unfaced batt insulation.)
- ☐ Hydraulically designed systems:
 1. Hydraulic data nameplate information. (22.1.3(31))
 - a. The minimum rate of water application (density).
 - b. The location and size of the design area.
 - c. Inside and outside hose stream allowances as actually provided.
 - d. Required flow and residual pressure at base of riser.
 - e. Occupancy classification.
 2. Hydraulic reference points shall be indicated on the plan corresponding with hydraulic calculations sheets. (22.1.3(34))



Lee Fire & Rescue Department

Chief of Department Scott M. Nemet • Assistant Chief Joseph P. Lombardo

20 George Bennett Road, Lee, NH 03861

Phone: (603) 659-5411 Fax: (603) 659-9611

"Protecting Yours Like It's Ours"

3. Protection areas per sprinkler head. (8.5.2)
 4. Provide a copy of the water flow test results (dated within six months of plan submission date) or verify the reliability and ability to meet the system demand at all times from a water source.
- ☐ Graph sheet. A graphic representation of the hydraulic demand shall be plotted on graph paper (Q1 85) or computer generated hydraulic program based upon flow data
1. Water supply curve
 2. Total sprinkler system hydraulic demand
 3. Hose streams demand
 4. In-Rack sprinkler demand (where applicable)

Tenant Fit-up

- ☐ Where existing systems are to be modified, sufficient details of the existing system shall be shown on the plans to determine effect of proposed modification on total system. (22.1.3(30))
- ☐ Provide shopping center key plan or building complete floor plan indicating the location of tenant space.
- ☐ Plans shall clearly indicate location and floor level of the hydraulic remote area and its design criteria.
- ☐ Work being performed in the hydraulic remote area shall include hydraulic calculations and water flow test results (date within 6 months of plan submission date).

Limited area sprinkler system:

- ☐ Provide key plan showing the room or space to be sprinklered. Provide location in the building and room number(s), floor, etc.
- ☐ Provide hydraulic calculations in accordance with NFPA 22.3; IBC 903.3.5.1.1
- ☐ When a valve is provided downstream from the domestic water control valve the limited area sprinkler system shall be supervised in accordance with IBC, 2000 Edition, Section 907.6.3 or International Plumbing Code 2000 Edition.



Lee Fire & Rescue Department

Chief of Department Scott M. Nemet • Assistant Chief Joseph P. Lombardo

20 George Bennett Road, Lee, NH 03861

Phone: (603) 659-5411 Fax: (603) 659-9611

"Protecting Yours Like It's Ours"

Storage Occupancy:

Miscellaneous Storage < twelve feet in height:

- ☐ Plans shall clearly indicate commodity classification, maximum storage height, proposed storage arrangement, widths and locations of all aisles. (7-2.3.2.2)
- ☐ Plans shall clearly indicate roof/ceiling height within storage area.

Storage Commodities

- ☐ Plans shall clearly indicate fire control approach for storage commodities, such as: (12.1;13.1)
- ☐ Plans shall clearly indicate commodity classification, maximum storage height, proposed storage arrangement, widths and location of all aisles.
- ☐ Plans shall clearly indicate minimum and maximum distance between the sprinkler deflector and the top of storage.
- ☐ Plans shall clearly indicate rack configuration (width and height) and flue spaces: (Single row, Double row, Multiple rows).
- ☐ Plans shall clearly indicate the method of storage, i.e.; wood pallets on racks, expanded plastic pallets on racks, solid shelving, opening shelving; or encapsulated wrapping materials.
- ☐ Plans shall clearly indicate interior small hose stations or approved alternative.

Manufacturers Data Sheet:

All submissions shall include the appropriate Manufacturers Data Sheets for the following:

- ☐ Pipe
- ☐ Fittings (Threaded, Grooved, Etc.)
- ☐ Valves (O.S. & Y., Butterfly, Etc.)
- ☐ Hangers/ Rod/ Fasteners/ Clamps
- ☐ Alarm Check Valve/ Retard Chamber/ Water Motor Alarm
- ☐ Swing Check Valves
- ☐ Fire Department Connections
- ☐ Sprinkler Heads/ Spray Nozzles
- ☐ Inspectors Test Connections/ Drain Assemblies
- ☐ Riser Manifolds
- ☐ Backflow Preventers/ RPZ's Valves



Lee Fire & Rescue Department

Chief of Department Scott M. Nemet • Assistant Chief Joseph P. Lombardo

20 George Bennett Road, Lee, NH 03861

Phone: (603) 659-5411 Fax: (603) 659-9611

"Protecting Yours Like It's Ours"

- ☐ Pressure Regulating Valves
- ☐ Dry Valves/ Preaction Valves/ Actuation Devices and Systems/ Trim
- ☐ Valve Supervisory Switches
- ☐ Water Flow Vane Switches
- ☐ Pressure Switches
- ☐ Fire Pumps/ Accessories
- ☐ Fire Pump Drivers/ Accessories
- ☐ Fire Pump Controllers
- ☐ Jockey Pumps
- ☐ Jockey Pump Controllers
- ☐ Relief Valves
- ☐ Fire Hose Valves, Fire Hose and Nozzles
- ☐ Special System Components (Foam, Antifreeze, Water Mist, Etc.)
- ☐ Other _____
- ☐ Other _____

Where multiple contractors are involved in the system design/ installation, plan approval requires concurrent submittals and review of the fire suppression and detection systems.

Special Notes

- ☐ Sprinkler systems required to be monitored off-site in accordance with IBC Section 901.6.
- ☐ Piping between the sprinkler system and a pressure actuated water flow alarm-initiating device shall be galvanized, nonferrous metal, or other approved corrosion resistant material. (1999 Revised NFPA 73:2-6.3)
- ☐ Plans shall clearly indicate the make, type, model, and size of dry pipe, pre-action, or deluge valves. (22.1.3(24); 22.1.3(25))
- ☐ Plans shall clearly indicate the water capacity in gallons of each dry pipe system. (7.2.3)
- ☐ Plans shall clearly indicate air pressure settings for valves and supervisory air functions at normal and abnormal conditions. (7.2.6.6)
- ☐ Information about antifreeze used (type and amount). (22.1.3(42))
- ☐ Calculations of loads for sizing and details of sway bracing (22.1.3(39))
- ☐ An approved reduced pressure principle backflow prevention device (RPZ-listed assembly) including approved indicating control valves shall be provided on all antifreeze systems. (2000 ICC International Plumbing, 3-5.31).



Lee Fire & Rescue Department

Chief of Department Scott M. Nemet • Assistant Chief Joseph P. Lombardo

20 George Bennett Road, Lee, NH 03861

Phone: (603) 659-5411 Fax: (603) 659-9611

"Protecting Yours Like It's Ours"

- ☐ An approved listed expansion chamber shall be provided on all antifreeze systems (7.6.3.1)
- ☐ Fire pump and booster fire pump installations shall comply with NFPA 20.

Hydraulic Calculations Forms

Hydraulic calculations shall be prepared on form sheets that include a summary sheet, detailed work sheets, and a graph sheets. (22.3)

- ☐ When multiple designs are required to protect various hazards with a common system area, separate calculations shall be provided for each hazard area.
- ☐ All code credits/exceptions utilized in the design must be clearly marked on the plan complete with the calculation and code cite referenced.
- ☐ Calculation summary sheet shall include: (22.3.2)
 1. Date
 2. Location
 3. Description of Hazard
 4. System Design Requirements
 - a. Total design area (ft²)
 - b. Minimum rate of water application (density), gpm/ft².
 - c. Area of coverage per sprinkler.
 5. Total system demand at base of riser. Water for inside and outside hose streams shall be represented as actually provided.
 6. Allowance for in-rack sprinklers, gpm.
 7. Limitation (dimension, flow, and pressure) on extended coverage or other listed special sprinklers.
- ☐ Graph sheet. A graphic representation of the hydraulic demand shall be plotted on graph paper (Q) or computer generated hydraulic program based up:
 1. Flow rate
 2. Total sprinkler system hydraulic demand including hose streams.
- ☐ Detailed Worksheets (22.3.3)
 1. Sheet number
 2. Sprinkler description and discharge constant (K)
 3. Hydraulic reference points
 4. Flow in GPM
 5. Pipe size
 6. Pipe Length, center-to-center of fittings
 7. Equivalent pipe lengths for fitting and devices
 8. Friction loss in psi of pipe



Lee Fire & Rescue Department

Chief of Department Scott M. Nemet • Assistant Chief Joseph P. Lombardo

20 George Bennett Road, Lee, NH 03861

Phone: (603) 659-5411 Fax: (603) 659-9611

"Protecting Yours Like It's Ours"

9. Total friction loss between reference points
10. In-rack sprinkler demand balanced on ceiling demand
11. Elevation head in psi between reference point
12. Velocity pressure and normal pressure if included in calculations
13. Notes to indicate starting points or reference to other sheets or to clarify data shown
14. Diagram to accompany gridded system calculations to indicate flow quantities and directions for lines with sprinklers operating in the remote area.
15. Combine K-factor calculations for sprinklers on drops, armovers, or sprigs where calculations do not begin at the sprinkler.